



PO Box 4195 * Sunland, CA 91041
Tel: (818) 352-8282 Fax: (818) 450-0326
www.sundecorating.com

FIRE DEPARTMENT REGULATIONS

For exhibits, exhibitions, displays and trade shows - public and private

BOOTH CONSTRUCTION

Booths, platforms and space dividers shall be of materials that are flame retardant or rendered so, satisfactory to the Fire Department representatives.

Covering for counters or tables used within or as a part of the booth shall be flame retardant.

All electrical wiring and apparatuses will be of a wire UL type approved.

FIRE DEPARTMENT

The following are prohibited in this show.

1. Display and operation of any heater, barbecue, heat-producing or open flame device: candles, lamps, lanterns, torches, etc.
2. Display or operate any electrical, mechanical, or chemical device which may be deemed hazardous by the Fire Department.
3. Use or storage of flammable liquids and dangerous chemicals.
4. Display any internal combustion engine (***SPECIAL REQUIREMENTS AVAILABLE ON REQUEST.***)
5. Use of compressed gases - propane, butane, helium, etc. (*Permit available 32CF bottles 1/2 full or less.*)

OBSTRUCTION

Aisles and exits, as designated on approved show plans, shall be kept clean, clear and free of obstacles. Booth construction shall be substantial and fixed in position in specified area for the duration of the show. Easels, signs, etc. shall not be placed beyond the booth area into aisles.

Fire fighting equipment shall be provided and maintained in accessible, easily seen locations and may be required to be posted with designating signs.

FIRE-RETARDANT TREATMENT

All decorations, drapes, signs, banners, acoustical materials, cotton, paper, hay, straw, moss, split bamboo, plastic cloth, and similar materials shall be flame-retardant unless smaller than 1232 square inches (28" X 44") if separated from other combustibles by a minimum of 12" horizontally and 24" vertically. Oilcloth, tar paper, nylon and certain other plastic materials cannot be made flame-retardant and their use is prohibited.

COMBUSTIBLES

Literature on display shall be limited to reasonable quantities (*one day supply*). Reserve supplies shall be kept in closed containers and stored in a neat and compact manner in a location approved by the Fire Department. All exhibit and display empty cartons must be stored in an approved drayage area. If show is under a 24 hour approved manned Security Program, automobiles are allowed to retain 1 gallon or less in fuel and gas caps must be taped. Batteries to be disconnected and taped.